



North Carolina Department of Administration

Pat McCrory, Governor
Bill Daughtridge, Jr., Secretary

State Construction Office
Gregory A. Driver, PE, Director

June 5, 2014

DEPARTMENT:	Community Colleges	PROJECT:	Lafayette Hall - HVAC Renovations
AGENCY:	Fayetteville Technical Community College	PACKAGE:	Lafayette Hall - HVAC Renovations
CODE & ITEM:	-1793	SCO FILE#:	09-08255-02A
DESIGNER:	Stanford White, Inc.		

The final report, as-built drawings and electronic files were received by the State Construction Office and approved on June 5, 2014.

Chapter 600 of the State Construction Manual requires submission of these documents before final payment is made. If the Owner/Using Agency is satisfied with the accuracy and completeness of the final drawings and final report, all construction contracts are closed out on the project, and all other contractual obligations to the Owner have been met, final payment may be made to the designer.

Signature: Gregory A. Driver

Mailing Address:
1307 Mail Service Center
Raleigh, N.C. 27699-1307

Telephone (919) 807-4100
Fax (919) 807-4110
State Courier #56-02-01

Location:
301 N. Wilmington St., Suite 450
Raleigh, North Carolina 27601

An Equal Opportunity/Affirmative Action Employer

Work Order Number	Request Number	Department	Description
0016802		MAINT Maintenance	Call in work orders for the week of Feb 16-27 for the following: Room 108A in CBI hot; CUH 365 cold, GCB 211 cold; Admin rm 170 and rm 162 temp needs adjusting; CBI rms 123 & 127 cold; VCC men's restroom paper products in mens urinal; HEC outside water spigot leaking, Reva Dunn light out in office; CBI 123 cold; <u>SLC</u> welding shop is
Order Date: 02/27/15	Req Comp Date: 03/06/15	Dept Account: 21-620-97-527000-11203	
Type: HV Hvac Complaints	Building: CBI Business Industry	Plant Account: 21-620-97-527000-11203	
Trade: 4 Routine	Location:	Contact: Denise M. Kinnison	
Priority:		Phone/Ext: 678-8228	

Est Hours:	Actual Hours: 0.00
Est Labor:	Actual Labor: 0.00
Est Materials:	Actual Materials: 0.00
Est Comp Date: 03/06/15	Actual Comp Date: 02/27/15

Special Instructions:

adjusted temps
 CBI 108 A - 123 + 127 - 1hr
 CH 365 - 15mi
 GCB 211 - 15mi³⁰
 Admin 170-162 - 2 1/2 hr - cleaned Strainer
 CBI light - 1hr
 SLC Welding Shop - 30mi

HeC
Water Spigot 4hr

*cleaned Strainer Admin
 Junior 2 1/2 hr 170-162
 Robert 2 1/2 hr
 Rodney 2 1/2 hr*

Completed By: _____
 Completed By: _____
 Verified By: RW

Hours: 17 1/2
 Hours: _____
 Verified Date: 3-20-15

RW